

Continuous water monitoring at Station B (discharge from San Luis Drain), September 2010.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Sep-01-2010	14	24.2	11.0	4,950	29.8	2.2
Sep-02-2010	13	24.5	10.0	4,810	29.4	2.1
Sep-03-2010	13	25.8	9.8	4,790	26.5	1.8
Sep-04-2010	11	26.5	9.4	4,570	25.2	1.5
Sep-05-2010	10	26.7	9.7	4,670	27.0	1.4
Sep-06-2010	10	25.7	10.0	4,840	27.3	1.5
Sep-07-2010	12	26.5	10.0	4,740	26.1	1.7
Sep-08-2010	11	21.2	11.0	4,320	27.3	1.7
Sep-09-2010	12	20.5	11.0	4,360	24.6	1.6
Sep-10-2010	13	23.0	11.0	4,410	26.3	1.9
Sep-11-2010	14	25.2	9.5	4,470	26.3	2.0
Sep-12-2010	15	26.3	8.5	4,540	23.7	1.9
Sep-13-2010	16	21.9	8.7	4,600	24.2	2.1
Sep-14-2010	16	24.0	8.6	4,770	23.8	2.1
Sep-15-2010	16	23.8	8.4	4,500	19.4	1.6
Sep-16-2010	15	24.1	8.4	4,230	21.6	1.7
Sep-17-2010	17	24.8	8.1	4,200	17.7	1.6
Sep-18-2010	14	25.3	7.5	3,910	16.0	1.2
Sep-19-2010	13	25.0	7.8	3,890	16.7	1.1
Sep-20-2010	13	24.7	8.1	3,980	17.7	1.3
Sep-21-2010	12	24.1	7.0	4,030	16.9	1.1
Sep-22-2010	10	23.2	7.8	3,800	22.6	1.2
Sep-23-2010	10	22.6	7.7	4,140	20.2	1.0
Sep-24-2010	9	22.7	7.5	4,060	20.1	1.0
Sep-25-2010	8	22.8	7.5	4,020	21.3	0.9
Sep-26-2010	8	23.6	7.6	4,090	21.5	0.9
Sep-27-2010	7	23.4	8.3	4,270	20.4	0.8
Sep-28-2010	7	24.3	8.6	4,580	18.4	0.6
Sep-29-2010	7	25.2	8.4	4,640	17.2	0.7
Sep-30-2010	7	25.1	8.5	4,480	13.6	0.5
.
Mean	12	24.2	8.9	4,390	15.4	1.4
Total					Total	
Acre-feet	930				(lbs)	43
Load						
Limitation for September 2010 (lbs)						264