

Continuous water monitoring at Station B (discharge from San Luis Drain), November 2010.

PARAMETER	Flow	Temperature	Boron	Specific Conductance	Selenium (total)	Selenium (total) Load
DATA						
SOURCE	USBR	USBR	CVRWQCB	CVRWQCB	CVRWQCB	Computed
UNITS	cfs	°C	mg/L	µS/cm	µg/L	lbs
Nov-01-2010	13	16.2	7.3	3,880	8.0	0.6
Nov-02-2010	13	16.4	6.6	3,650	7.6	0.5
Nov-03-2010	12	16.9	5.7	3,530	7.9	0.5
Nov-04-2010	13	17.4	4.8	3,390	6.3	0.4
Nov-05-2010	12	17.9	5.1	3,110	6.9	0.5
Nov-06-2010	13	17.9	5.6	3,250	8.3	0.6
Nov-07-2010	14	17.0	6.3	3,470	9.9	0.7
Nov-08-2010	14	15.9	6.6	3,940	9.9	0.7
Nov-09-2010	15	14.7	5.5	3,650	8.2	0.7
Nov-10-2010	15	14.9	5.3	3,440	9.3	0.8
Nov-11-2010	15	13.6	5.1	3,270	11.1	0.9
Nov-12-2010	14	13.3	4.8	3,320	11.7	0.9
Nov-13-2010	13	13.3	4.6	2,910	10.9	0.8
Nov-14-2010	14	13.3	8.0	3,670	14.0	1.0
Nov-15-2010	15	13.8	8.4	4,350	17.3	1.4
Nov-16-2010	15	14.3	8.3	4,450	21.5	1.8
Nov-17-2010	16	14.2	8.1	4,440	21.1	1.8
Nov-18-2010	14	14.0	7.3	4,220	16.1	1.2
Nov-19-2010	15	13.7	7.0	4,020	16.2	1.3
Nov-20-2010	19	13.0	7.1	3,930	16.0	1.6
Nov-21-2010	24	12.0	8.1	4,350	26.2	3.4
Nov-22-2010	32	11.8	8.1	4,310	22.6	3.9
Nov-23-2010	28	11.5	7.4	3,970	24.0	3.6
Nov-24-2010	17	9.7	7.7	4,280	22.9	2.1
Nov-25-2010	18	8.5	9.0	4,380	38.3	3.8
Nov-26-2010	28	8.4	8.4	4,630	41.2	6.3
Nov-27-2010	30	8.6	8.1	4,450	37.3	6.0
Nov-28-2010	26	8.4	8.4	4,420	30.7	4.3
Nov-29-2010	27	8.0	9.6	5,090	48.4	7.0
Nov-30-2010	24	8.0	7.9	4,580	45.6	5.9
.	.	.	.	.	.	.
<b>Mean</b>	18	13.2	7.0	3,950	19.2	2.2
<b>Total</b>					<b>Total</b>	
<b>Acre-feet</b>	1,070				<b>(lbs)</b>	65
<b>Load</b>						
<b>Limitation for November 2010 (lbs)</b>						260