

Continuous water monitoring at Station B (discharge from San Luis Drain), June 2014.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
<b>DATA</b>							
<b>SOURCE</b>	<b>SLDMWA</b> ♦	<b>SLDMWA</b>	<b>SLDMWA</b>	<b>SLDMWA/USBR</b>	<b>USBR</b>	<b>USBR</b>	<b>Calculated</b>
<b>UNITS</b>	<b>cfs</b>	<b>°C</b>	<b>µS/cm</b>	<b>mg/L</b>	<b>mg/L</b>	<b>µg/L</b>	<b>lbs</b>
Jun-01-2014	5	24.8	8,140		16.0	12.3	0.3
Jun-02-2014	5	23.2	8,410		16.0	16.6	0.4
Jun-03-2014	3	22.4	8,500		16.0	15.7	0.3
Jun-04-2014	3	25.1	8,660		16.0	18.4	0.3
Jun-05-2014	4	27.9	8,750		17.0	6.1	0.1
Jun-06-2014	2	25.9	8,800		16.0	5.3	0.1
Jun-07-2014	1	26.9	8,860		16.0	4.7	0.0
Jun-08-2014	3	28.6	8,930		16.0	4.6	0.1
Jun-09-2014	1	30.3	9,050	55	16.0	6.1	0.0
Jun-10-2014	0	27.9	9,080		15.0	8.0	0.0
Jun-11-2014	0	26.1	9,130		15.0	10.9	0.0
Jun-12-2014	1	23.4	9,460		14.0	13.5	0.1
Jun-13-2014	7	22.0	9,150		15.0	12.6	0.5
Jun-14-2014	6	24.1	8,790		15.0	11.2	0.4
Jun-15-2014	5	22.4	8,510		13.0	11.7	0.3
Jun-16-2014	6	21.5	8,390	62	13.0	11.1	0.3
Jun-17-2014	6	20.1	8,240		13.0	10.9	0.3
Jun-18-2014	8	23.7	7,630		14.0	11.2	0.5
Jun-19-2014	10	25.8	7,210		13.0	12.3	0.7
Jun-20-2014	9	25.3	7,470		17.0	11.9	0.6
Jun-21-2014	13	24.7	8,720		18.0	14.4	1.0
Jun-22-2014	19	23.9	8,660		14.0	28.9	3.0
Jun-23-2014	12	24.9	7,570	56	12.0	36.9	2.3
Jun-24-2014	12	26.8	7,230		12.0	36.7	2.5
Jun-25-2014	10	25.1	6,690		11.0	37.4	2.1
Jun-26-2014	10	24.5	6,150		9.8	33.6	1.8
Jun-27-2014	10	24.9	5,840		11.0	35.5	1.9
Jun-28-2014	14	25.3	6,340		13.0	32.1	2.4
Jun-29-2014	12	26.7	7,380		17.0	21.4	1.3
Jun-30-2014	7	30.7	8,710	65	17.0	16.1	0.6
<b>Mean</b>	<b>7</b>	<b>25.2</b>	<b>8,150</b>	<b>60</b>	<b>14.6</b>	<b>16.9</b>	<b>0.8</b>
						<b>Total (lbs)</b>	<b>25</b>
<b>Load</b>							
<b>Limitation for June 2014 (lbs)</b>							<b>69</b>