

Continuous water monitoring at Station B (discharge from San Luis Drain), October 2016.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
<b>DATA</b>							
<b>SOURCE</b>	<b>SLDMWA</b> ♦	<b>SLDMWA</b>	<b>SLDMWA</b>	<b>SLDMWA/USBR</b>	<b>USBR</b>	<b>USBR</b>	<b>Calculated</b>
<b>UNITS</b>	<b>cfs</b>	<b>°C</b>	<b>µS/cm</b>	<b>mg/L</b>	<b>mg/L</b>	<b>µg/L</b>	<b>lbs</b>
Oct-01-2016	6	17.2	3,850		6.1	7.2	0.2
Oct-02-2016	6	16.8	3,510		5.4	6.1	0.2
Oct-03-2016	6	15.5	3,330		5.2	5.6	0.2
Oct-04-2016	6	16.7	3,380		5.1	5.6	0.2
Oct-05-2016	6	16.3	3,110		4.1	5.9	0.2
Oct-06-2016	7	17.5	2,900		3.7	5.1	0.2
Oct-07-2016	7	18.2	2,800		3.5	4.6	0.2
Oct-08-2016	7	20.1	2,740		3.3	4.1	0.2
Oct-09-2016	7	21.5	2,690		3.2	4.5	0.2
Oct-10-2016	7	21.9	2,630		3.1	4.5	0.2
Oct-11-2016	7	18.2	2,620		3.1	4.6	0.2
Oct-12-2016	8	19.3	2,520		3.1	4.5	0.2
Oct-13-2016	8	19.3	2,490		2.9	4.5	0.2
Oct-14-2016	8	18.6	2,430		2.8	4.2	0.2
Oct-15-2016	9	20.6	2,380		2.7	4.1	0.2
Oct-16-2016	9	18.3	2,370		2.7	4.3	0.2
Oct-17-2016	8	17.8	2,350		2.7	4.4	0.2
Oct-18-2016	7	15.8	2,350		2.7	4.4	0.2
Oct-19-2016	8	16.8	2,290		2.8	4.6	0.2
Oct-20-2016	8	17.6	2,270		2.7	3.9	0.2
Oct-21-2016	8	18.7	2,280		2.7	4.2	0.2
Oct-22-2016	7	18.6	2,260		2.6	3.9	0.2
Oct-23-2016	8	20.4	2,290		2.6	4.0	0.2
Oct-24-2016	7	19.2	2,300		2.6	4.1	0.2
Oct-25-2016	7	19.6	2,310		2.5	3.8	0.1
Oct-26-2016	7	19.2	2,300		2.9	3.9	0.1
Oct-27-2016	7	16.9	2,340		2.7	3.8	0.1
Oct-28-2016	11	17.7	2,280		2.6	3.4	0.2
Oct-29-2016	14	19.8	2,180		2.4	3.0	0.2
Oct-30-2016	22	17.5	2,170		2.4	3.0	0.4
Oct-31-2016	11	17.0	2,200		2.4	3.0	0.2
<b>Mean</b>	<b>8</b>	<b>18.3</b>	<b>2,580</b>		<b>3.2</b>	<b>4.4</b>	<b>0.2</b>
						<b>Total (lbs)</b>	<b>6</b>
<b>Load</b>							
<b>Limitation for October 2016 (lbs)</b>							<b>131</b>