Continuous water monitoring at Station B (discharge from San Luis Drain), April 2017.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Apr-01-2017	11	16.9	6,340		10.7	33.6	1.0
Apr-02-2017	9	17.7	6,150		10.6	33.7	0.8
Apr-03-2017	7	16.5	6,250		10.5	33.1	0.6
Apr-04-2017	7	17.8	6,330		10.9	33.3	0.6
Apr-05-2017	7	19.9	6,400		9.8	28.4	0.5
Apr-06-2017	6	15.1	6,150		9.4	27.4	0.5
Apr-07-2017	6	14.4	5,980		9.2	27.1	0.5
Apr-08-2017	7	12.6	5,770		9.1	27.0	0.5
Apr-09-2017	16	12.8	5,690		8.5	25.5	1.1
Apr-10-2017	32	15.0	4,400		5.6	18.0	1.5
Apr-11-2017	24	16.0	2,930		7.0	18.5	1.2
Apr-12-2017	10	17.9	2,650		7.6	12.6	0.3
Apr-13-2017	6	15.8	3,400		11.3	11.1	0.2
Apr-14-2017	5	12.1	4,750		13.4	12.8	0.2
Apr-15-2017	5	14.3	5,850		14.5	13.0	0.2
Apr-16-2017	5	13.4	6,720		14.7	16.6	0.2
Apr-17-2017	5	14.7	7,070		13.9	21.2	0.6
Apr-18-2017	5		6,910		13.1	18.0	0.5
Apr-19-2017	15	19.8	7,910		10.1	24.6	2.1
Apr-20-2017	37	16.7	6,480		8.2	19.5	3.9
Apr-21-2017	19	17.6	6,450		4.2	5.1	0.5
Apr-22-2017	8	17.8	4,900		5.8	8.6	0.4
Apr-23-2017	6	17.4	3,560		7.5	10.2	0.3
Apr-24-2017	5	16.2	3,660		9.8	16.5	0.5
Apr-25-2017	5	16.3	4,090		9.8	16.7	0.4
Apr-26-2017	5	18.3	4,670		12.6	10.7	0.3
Apr-27-2017	3	17.8	5,140		13.5	10.6	0.2
Apr-28-2017	1	18.6	5,450		14.2	10.5	0.1
Apr-29-2017	3	19.5	5,650		14.7	10.6	0.2
Apr-30-2017	3	20.1	6,050		15.0	10.4	0.2
Mean	10	16.5	5,460		10.5	18.8	0.7
						Total (lbs)	20
Load Limitation for April 2017 (lbs)							177