

Continuous water monitoring at Station B (discharge from San Luis Drain), November 2017.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (total)	Selenium (total) Load
DATA							
SOURCE	SLDMWA ♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	lbs
Nov-01-2017	11	14.9	2,310		2.8	2.2	0.1
Nov-02-2017	11	13.8	2,280		2.8	2.0	0.1
Nov-03-2017	11	15.5	2,280		2.8	2.2	0.1
Nov-04-2017	11	15.6	2,290		2.8	2.1	0.1
Nov-05-2017	10	11.5	2,330		2.9	2.1	0.1
Nov-06-2017	10	11.2	2,360		2.9	2.1	0.1
Nov-07-2017	10	11.6	2,360		2.9	2.0	0.1
Nov-08-2017	11	13.3	2,320		2.8	2.0	0.1
Nov-09-2017	11	17.0	2,410		2.9	1.7	0.1
Nov-10-2017	10	15.7	2,450		2.8	1.7	0.1
Nov-11-2017	10	14.3	2,320		2.7	1.7	0.1
Nov-12-2017	11	13.3	2,340		2.7	1.7	0.1
Nov-13-2017	11	14.1	2,300		2.7	1.7	0.1
Nov-14-2017	10	16.1	2,320		2.7	1.7	0.1
Nov-15-2017	11	15.2	2,440		2.8	1.7	0.1
Nov-16-2017	11	16.0	2,420		2.8	1.7	0.1
Nov-17-2017	11	13.9	2,330		2.7	1.7	0.1
Nov-18-2017	11	11.0	2,330		2.6	1.7	0.1
Nov-19-2017	11	11.2	2,290		2.6	1.6	0.1
Nov-20-2017	11	14.5	2,400		2.7	1.7	0.1
Nov-21-2017	10	13.1	2,350		2.6	1.6	0.1
Nov-22-2017	10	14.8	2,270		2.6	1.7	0.1
Nov-23-2017	10	17.0	2,270		2.6	1.7	0.1
Nov-24-2017	10	18.1	2,320		2.7	1.7	0.1
Nov-25-2017	10	15.1	2,370		2.7	1.7	0.1
Nov-26-2017	10	15.3	2,300		2.6	1.7	0.1
Nov-27-2017	10	13.1	2,360		2.7	1.7	0.1
Nov-28-2017	10	10.5	2,420		2.7	1.7	0.1
Nov-29-2017	10	10.5	2,350		2.8	1.7	0.1
Nov-30-2017	10	10.3	2,350		2.8	1.7	0.1
Mean	10	13.9	2,340		2.7	1.8	0.1
						Total (lbs)	3
Load							
Limitation for November 2017 (lbs)							115