

Continuous water monitoring at Station B (discharge from San Luis Drain), May 2018.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (B3) (total)	Selenium (B2) (total)	Selenium (total) Load
DATA SOURCE UNITS	SLDMWA [‡] cfs	SLDMWA °C	SLDMWA µS/cm	SLDMWA/USBR mg/L	USBR mg/L	SLDMWA µg/L	USBR µg/L	Calculated lbs
May-01-2018	19		2,820		4.6	3.2	3.2	0.3
May-02-2018	17		2,850		4.5	3.2	3.2	0.3
May-03-2018	9		2,780		4.4	3.2	3.2	0.2
May-04-2018	15		2,810		4.4	2.7	2.7	0.2
May-05-2018	14		2,830		4.3	2.7	2.7	0.2
May-06-2018	14		2,990		5.0	2.9	2.9	0.2
May-07-2018	14		3,470		6.7	3.2	3.2	0.2
May-08-2018	13		2,940		4.9	2.6	2.6	0.2
May-09-2018	13		2,980		5.2	2.7	2.7	0.2
May-10-2018	13		3,010		5.0	2.8	2.8	0.2
May-11-2018	11		3,040		5.2	2.7	2.7	0.2
May-12-2018	12		3,130		5.5	2.4	2.4	0.2
May-13-2018	11		3,210		3.7	2.5	2.5	0.1
May-14-2018	11		3,200		3.6	2.6	2.6	0.2
May-15-2018	11		3,160		4.8	2.7	2.7	0.2
May-16-2018	12		3,140		4.7	2.8	2.8	0.2
May-17-2018	12		3,190		4.9	2.9	2.9	0.2
May-18-2018	12		3,320		5.0	3.0	3.0	0.2
May-19-2018	11		3,370		5.1	2.6	2.6	0.2
May-20-2018	11		3,370		5.0	2.7	2.7	0.2
May-21-2018	11		3,390		5.3	2.7	2.7	0.2
May-22-2018	11					2.6	2.6	0.2
May-23-2018	10					2.8	2.8	0.2
May-24-2018	11					2.8	2.8	0.2
May-25-2018	12					2.6	2.6	0.2
May-26-2018	13					2.6	2.6	0.2
May-27-2018	12					2.7	2.7	0.2
May-28-2018	12					2.6	2.6	0.2
May-29-2018	12		3,310		4.4	2.4	2.4	0.2
May-30-2018	11		3,290		4.3	2.8	2.8	0.2
May-31-2018	10		3,260		4.2	2.4	2.4	0.1
Mean	12	NA	3,120		4.8	2.7	2.7	0.2
							Total (lbs)	5.6
Load								
Limitation for May 2018 (lbs)								197