Continuous water monitoring at Station B (discharge from San Luis Drain), September 2018.

PARAMETER	Flow	Temperature	Specific Conductance	Total Suspended Solids	Boron	Selenium (B3) (total)	Selenium (B2) (total)	Selenium (total) Load
DATA SOURCE	SLDMWA♦	SLDMWA	SLDMWA	SLDMWA/USBR	USBR	SLDMWA	USBR	Calculated
UNITS	cfs	°C	µS/cm	mg/L	mg/L	µg/L	µg/L	lbs
Sep-01-2018	2		2,790		2.9	2.8	2.8	0.0
Sep-02-2018	3		2,620		2.8	2.6	2.6	0.0
Sep-03-2018	3		2,440		2.7	2.8	2.8	0.0
Sep-04-2018	4		2,620		3.1	3.3	3.3	0.1
Sep-05-2018	4		2,700		3.4	3.5	3.5	0.1
Sep-06-2018	4		2,630		3.3	3.6	3.6	0.1
Sep-07-2018	4		2,460		3.0	3.6	3.6	0.1
Sep-08-2018	4		2,330		2.9	3.5	3.5	0.1
Sep-09-2018	4		2,260		2.9	3.2	3.2	0.1
Sep-10-2018	4		2,280		2.9	3.3	3.3	0.1
Sep-11-2018	4		2,310		3.0	3.3	3.3	0.1
Sep-12-2018	4		2,340		3.0	3.1	3.1	0.1
Sep-13-2018	4		2,410		3.1	3.3	3.3	0.1
Sep-14-2018	4		2,430		3.1	3.5	3.5	0.1
Sep-15-2018	5		2,460		3.1	3.3	3.3	0.1
Sep-16-2018	5		2,530		3.1	3.2	3.2	0.1
Sep-17-2018	5		2,550		3.2	3.4	3.4	0.1
Sep-18-2018	6		2,560		3.1	3.5	3.5	0.1
Sep-19-2018	6		2,540		3.1	3.7	3.7	0.1
Sep-20-2018	6		2,520		3.0	3.7	3.7	0.1
Sep-21-2018	6		2,410		2.9	3.5	3.5	0.1
Sep-22-2018	6		2,310		2.8	3.6	3.6	0.1
Sep-23-2018	6		2,230		2.7	3.5	3.5	0.1
Sep-24-2018	6		2,180		2.6	3.5	3.5	0.1
Sep-25-2018	6		2,090		2.5	3.9	3.9	0.1
Sep-26-2018	6		2,030		2.4	3.6	3.6	0.1
Sep-27-2018	6		2,050		2.5	3.7	3.7	0.1
Sep-28-2018	6		1,980		2.3	3.3	3.3	0.1
Sep-29-2018	6		2,020		2.3	3.6	3.6	0.1
Sep-30-2018	6		2,030		2.3	3.3	3.3	0.1
Mean	5	NA	2,370		2.9	3.4	3.4	0.1
							Total (lbs)	2.7
Load Limitation for September 2018 (lbs)								235